



# Compliance Statement

## Screened Category 6 ISO/IEC, EN & TIA/EIA Communication Cable

**Draka Comteq Identification Cat 6 U/FTP LSHF - 1000647**

**Category 6, Individual S-Foil Screened without Overall Screen  
100  $\Omega$ , 4 Twisted Pairs, 23 AWG, Flame Retardant, LS0H, Copper Cable**

**Draka Comteq UK, Ltd.  
Crowther Road, Washington  
Tyne and Wear, NE8 0AQ, England**

***Compliance Statement No. 108416***

*This Screened ISO/IEC, EN & TIA/EIA Communication Cable has been tested by 3P Third Party Testing and complies with the Category 6 performance requirements of 2<sup>nd</sup> edition ISO/IEC Generic Cabling Standard 11801, CENELEC Generic Cabling Standard EN 50173-1:2007, ANSI/TIA/EIA Generic Cabling Standard 568-B.2-1 (modified to cover individual foil screened cables) and IEC Cable Standard 61156-5, the requirements of CENELEC Cable Standard EN 50288-5-1. Flame safety is verified according to IEC 60332-1-2, IEC 61034-1, IEC 61034-2, incl. amendment 1, and IEC 60754-2. The cable has EMC Performance Rating 8. The Compliance Statement may be suspended or withdrawn if cable fails to pass a Maintenance Testing performed at 6 or 12 month intervals.*

Hoersholm, 4<sup>th</sup> August 2008

*Ole Lambertsen*

Ole Lambertsen  
Test Responsible

Hoersholm, 4<sup>th</sup> August 2008

*Paul Villien*

Poul Villien  
Coordinating Manager